

# PRODUCT PERFORMANCE RATING

**Document ID 1630413471-aa-b8c6e985**

Issued on: 31 August 2021 - Délivré le : 31 août 2021

This product is certified by Eurovent Certita Certification as mentioned on:  
Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :

**Certificate N° 94.01.198**

**This document is valid at the date of issue - Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

*Ce document est valide à la date d'édition - Vérifiez la date de validité sur [www.eurovent-certification.com](http://www.eurovent-certification.com)*

Certification programmes / Programmes de certification

Product type / Type de produit

Model name / Nom du modèle

Range / Gamme

Participant / Titulaire

Brand / Marque

Air conditioners

Air to air, split, reversible ( $\leq 12$  kW)

AOYG24KATA/AUXG24KVLA

AUXG\*\*K

FUJITSU GENERAL (Euro) GmbH

FUJITSU

This performance certificate is delivered for the following project

Project Name	Project compagny	Project Reference	Project location
<i>Nom du projet</i>	<i>Nom de la société</i>	<i>Project Reference</i>	<i>Localisation du projet</i>
round	viacom vs	belgrade	Serbia

# PRODUCT PERFORMANCE RATING

Document ID 1630413471-aa-b8c6e985

Issued on: 31 August 2021 - Délivré le : 31 août 2021

This product is certified by Eurovent Certita Certification as mentioned on:  
Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :

## Certificate N° 94.01.198

This document is valid at the date of issue - Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)

Ce document est valide à la date d'édition - Vérifiez la date de validité sur [www.eurovent-certification.com](http://www.eurovent-certification.com)

FEATURE	VALUE	UNIT
<b>Seasonal Efficiency In Cooling</b>		
Pdesignc (Design Load Cooling)	6.8	kW
SEER (Seasonal Energy Efficiency Ratio)	5.9	
Qce (Annual electricity consumption for cooling)	403	kWh/annum
SEER Class (Seasonal Energy Efficiency Ratio Class)	A+	
<b>Heating Average Climate</b>		
Pdesignh (Design load heating )	5.4	kW
SCOP (Reference SCOP)	3.8	
SCOP Class (Seasonal Coefficient Of Performance Class)	A	
Qhe (Annual electricity consumption for heating)	1988	kWh/annum
<b>Acoustic</b>		
LW0 env (A-weighted sound level outdoor near the envelope for non ducted units )	66	dB(A)
Lw1 env (A-weighted sound power level indoor unit 1 (non ducted))	59	dB(A)
<b>Cooling PL CondB</b>		
Pc @ 30°C (Declared Cooling Capacity @ 30°C)	5.01	kW
EER @ 30°C (Declared Energy Efficiency @ 30°C )	4.28	
<b>Standard Cooling/Cooling PL Cond A</b>		
Pc (Total Cooling Capacity)	6.8	kW
Pec (Effective Power Input for Cooling (for chilled water cooled Close Control units only)	2.26	kW
EER (Energy Efficiency Ratio)	3.01	
<b>Cooling PL CondC</b>		
Pc @ 25°C (Declared Cooling Capacity @ 25°C)	3.22	kW
EER @ 25°C (Declared Energy Efficiency @ 25°C)	6.84	
<b>Cooling PL CondD</b>		
Pc @ 20°C (Declared Cooling Capacity @ 20°C)	1.99	kW
EER @ 20°C (Declared Energy Efficiency @ 20°C )	11.31	
<b>Standard Heating</b>		
Ph (Heating Capacity)	7.5	kW
Peh (Net Electric Power Consumption for Heating Only application )	2.08	kW
COP (Coefficient Of Performance)	3.61	

# PRODUCT PERFORMANCE RATING

Document ID 1630413471-aa-b8c6e985

Issued on: 31 August 2021 - Délivré le : 31 août 2021

This product is certified by Eurovent Certita Certification as mentioned on:  
Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :

## Certificate N° 94.01.198

This document is valid at the date of issue - Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)

Ce document est valide à la date d'édition - Vérifiez la date de validité sur [www.eurovent-certification.com](http://www.eurovent-certification.com)

Heating PL CondA		
Ph @ -7°C (Declared Heating Capacity @ -7°C)	4.78	kW
COP @ -7°C (Declared Coefficient Of Performances @ -7°C)	2.37	
Heating PL CondB		
Ph @ +2°C (Declared Heating Capacity @ +2°C)	2.91	kW
COP @ 2°C (Declared Coefficient Of Performances @ 2°C)	3.53	
Heating PL CondC		
Ph @ +7°C (Declared Heating Capacity @ +7°C)	1.87	kW
COP @ +7°C (Declared Coefficient Of Performances @ +7°C)	5.54	
Heating PL CondD		
Ph @ +12°C (Declared Heating Capacity @ +12°C)	1.8	kW
COP @ +12°C (Declared Coefficient Of Performances @ +12°C)	6.94	
Bivalent Point		
Tbiv (Bivalent Temperature)	-7	°C
COP @ Tbiv (Declared coefficient of performances at bivalent temperature condition)	2.37	
Ph TBiv (Heating capacity at bivalent temperature)	4.78	kW
TOL Runing Test		
TOL (Operating LimitTemperature )	-15	°C
Ph @ TOL (Declared Heating Capacity @ TOL)	4.63	kW
COP @ TOL (Declared Coefficient Of Performances @ TOL)	2.28	
Poffc		
Poff (Power consumption in off mode)	4	W
Psb		
Psb (Power consumption in standby mode cooling (Paux, cooling))	4	W
Ptoc		
Pto (Power consumption in thermostat off mode)	4	W
Pck		
Pck (Power consumption of the crankcase heater )	0	W
General		
Main Power Supply (Voltage (V) - Phase - Frequency (Hz))	230-1-50	
Refrigerant	R32	

# PRODUCT PERFORMANCE RATING

## Document ID 1630413471-aa-b8c6e985

Issued on: 31 August 2021 - Délivré le : 31 août 2021

This product is certified by Eurovent Certita Certification as mentioned on:  
Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :

## Certificate N° 94.01.198

This document is valid at the date of issue - Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)

Ce document est valide à la date d'édition - Vérifiez la date de validité sur [www.eurovent-certification.com](http://www.eurovent-certification.com)

FEATURE	VALUE	UNIT
General		
Refr. Line (Refrigerant Line. If possible )	5,0 m	m
Mounting (Mounting Type)	Cassette	