



# PRODUCT PERFORMANCE RATING

Document ID 050520201519-12242342

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

## Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	FUJITSU
Range	ASY**L
Product référence	AOYG30LMTA/ASYG30LMTA

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
ASYG30LMTA - AOYG30LMTA		BEOGRAD	Serbia

FEATURE	VALUE	UNIT
<b>STANDARD COOLING/COOLING PL COND A</b>		
Pc	8.00	kW
Pec	2.33	kW
EER	3.43	



# PRODUCT PERFORMANCE RATING

Document ID 050520201519-12242342

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>STANDARD HEATING</b>		
Ph	8.80	kW
Peh	2.41	kW
COP	3.65	

FEATURE	VALUE	UNIT
<b>ACOUSTIC</b>		
LwO env	67	dB(A)
LwI1 env	65	dB(A)

FEATURE	VALUE	UNIT
<b>COOLING PL CONDB</b>		
Pc @ 30°C	5.89	kW
EER @ 30°C	5.06	



# PRODUCT PERFORMANCE RATING

Document ID 050520201519-12242342

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL CONDC</b>		
Pc @ 25°C	4.17	kW
EER @ 25°C	7.77	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDD</b>		
Pc @ 20°C	4.18	kW
EER @ 20°C	10.21	

FEATURE	VALUE	UNIT
<b>SEASONAL EFFICIENCY IN COOLING</b>		
Pdesignc	8.00	kW
SEER	6.30	
Qce	441.00	kWh/annum
SEER Class	A++	



# PRODUCT PERFORMANCE RATING

Document ID 050520201519-12242342

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL CONDA</b>		
Ph @ -7°C	5.75	kW
COP @ -7°C	2.87	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDB</b>		
Ph @ +2°C	4.21	kW
COP @ 2°C	4.12	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDC</b>		
Ph @ +7°C	3.06	kW
COP @ +7°C	5.87	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDD</b>		
Ph @ +12°C	3.61	kW
COP @ +12°C	7.18	



# PRODUCT PERFORMANCE RATING

Document ID 050520201519-12242342

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING AVERAGE CLIMATE</b>		
Pdesignh	6.50	kW
SCOP	4.10	
SCOP Class	A+	
Qhe	2193.00	kWh/annum

FEATURE	VALUE	UNIT
<b>BIVALENT POINT</b>		
Tbiv	-7	°C
COP @ Tbiv	2.87	
Ph TBiv	5.75	kW

FEATURE	VALUE	UNIT
<b>TOL RUNING TEST</b>		
TOL	-15.00	°C
COP @ TOL	2.32	
Ph @ TOL	5.64	kW



# PRODUCT PERFORMANCE RATING

Document ID 050520201519-12242342

Issued on 5 May 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.198**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>POFFC</b>		
Poff	5.00	W

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psb	5.00	W

FEATURE	VALUE	UNIT
<b>PTOC</b>		
Pto	2.00	W

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Main Power Supply	230-1-50	
Refrigerant	R410A	
Refr. Line	5,0 m	m
Mounting	Wall mounted	